



Bureau Veritas
Consumer Products Services
Germany GmbH
Businesspark A96
86842 Türkheim
Germany
+ 49 (0) 40 740 41 - 0
cps-tuerkheim@de.bureauveritas.com

Certification body of BV CPS GmbH
Accredited according to EN 45011 -
ISO / IEC Guide 65

Certificate of compliance

Applicant: Omnik New Energy Co., Ltd.
Xinghu Road No.218 bioBAY Park A4-314
215123 Suzhou
China

Product: Automatic disconnection device between a generator
and the public low-voltage grid

Model: Omniksol-13k-TL; Omniksol-17k-TL;
Omniksol-20k-TL

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with Engineering Recommendation G59/2 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with isolating function that can access the distribution network provider at any time.

Applied rules and standards:

DIN V VDE V 0126-1-1:2006-02 (Redundancy) and Engineering Recommendation G59/2: The Omniksol-20k-TL, Omniksol-17k-TL, Omniksol-13k-TL are rated >16A and ≤ 50kW (3 phase). The default values for "Small Power Stations" on the low-voltage grid were verified.

Distribution Code: Modification to the Distribution Code to implement a change to Engineering Recommendation G59/2 relating to the limits of DC injection April 2011.

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: OMK-12AP0902FCSP-G59/2
Certificate number: U13-0055
Date of issue: 2013-01-31 **Valid until:** 2016-01-30

Certification body

Dieter Zitzmann

