



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA170191

Date of Issue: 20 February 2017

Class Description: Non-Declared
Product Description: Grid-tied PV Inverter

Additional Models

Omniksol-5k-TL2-TH

Omniksol-4k-TL2-TH

Description

Input: 1000Vdc Max, MPP voltage range 260-800Vdc I_{sc} 11/11A
Output: 3/N/PE 230/400V~ 50Hz 7.6A 5000VA

Input: 1000Vdc Max, MPP voltage range 260-800Vdc I_{sc} 11/11A
Output: 3/N/PE 230/400V~ 50Hz 7.4A 4000VA



For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 20-02-17 170191/2