



BV LCIE
CHINA N° 1466AS06OMK14078-N1
Number

This attestation replaces the attestation
N° 1466AS06OMK14078
which was cancelled

ATTESTATION of conformity with European Directives

Product: Grid-tied photovoltaic inverter
Reference Omniksol-3K-TL2-S, Omniksol-2.5K-TL2-S, Omniksol-2K-TL2,
Omniksol-1.5K-TL2, Omniksol-1k-TL2
Issued to Omnik New Energy Co., Ltd.
Address Xinghu Road No.218 bioBAY Park A4-314, 215123 Suzhou, China
Manufacturer Omnik New Energy Co., Ltd.
Technical characteristics See Page 2

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 62109-1:2010	OMK-14MA2225FTSP	28/08/2014
EN 62109-2:2011	OMK-14MA2226FTSP	28/08/2014

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China),), April 28th, 2017.



Dio Zhang
Operation Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com



L C I E

BV LCIE
CHINA N° 1466AS06OMK14078-N1
Number

This attestation replaces the attestation
N° 1466AS06OMK14078
which was cancelled

Ratings	Omniksol-3K-TL2-S	Omniksol-2.5K-TL2-S	Omniksol-2k-TL2
MPP DC voltage range [V]	120-450	120-450	120-450
Max DC voltage [V]	500	500	500
Input DC current [A]	18/18(Max)	18/18(Max)	18/18(Max)
Output AC voltage [V]	230V/50Hz/60Hz		
Output AC current [A].....	13(Nom) 14(Max)	11(Nom) 12,5(Max)	8,5(Nom) 12(Max)
Output power [VA].....	3000W(Nom) 3000VA(Max)	2500W(Nom) 2750VA(Max)	2000W(Nom) 2200VA(Max)

Ratings	Omniksol-1.5k-TL2	Omniksol-1k-TL2
MPP DC voltage range [V]	120-450	80-360
Max DC voltage [V]	500	500
Input DC current [A]	18/18(Max)	16/16(Max)
Output AC voltage [V]	230V/50Hz/60Hz	
Output AC current [A].....	6,5(Nom) 9(Max)	4,3(Nom) 5,8(Max)
Output power [VA].....	1500W(Nom) 1650VA(Max)	1000W(Nom) 1100VA(Max)

Shanghai (P.R. China),), April 28th, 2017.



Dio Zhang
Operation Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务有限公司
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com