



**BUREAU
VERITAS**

Certificate of compliance

Applicant: Omnik New Energy Co., Ltd.
Xinghu Road No.218 bioBAY Park A4-314,
215123 Suzhou
China

Product: PV Inverter with an automatic disconnection device between a generator and the public low-voltage grid

Model: Omniksol-3k-TL2-S
Omniksol-2.5k-TL2-S
Omniksol-2k-TL2
Omniksol-1.5k-TL2
Omniksol-1k-TL2

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with DIN V VDE V 0126-1-1:2006-02 and DIN V VDE V 0126-1-1/A1:2012-02 and DIN VDE V 0126-1-1:2013-08 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with insulating function, which the distribution network provider can access at any time.

Applied rules and standards:

DIN V VDE V 0126-1-1 (VDE V 0126-1-1):2006-02

Automatic disconnection device between a generator and the public low-voltage grid

DIN V VDE V 0126-1-1/A1 (VDE V 0126-1-1/A1):2012-02

Automatic disconnection device between a generator and the public low-voltage grid; Amendment 1.

DIN VDE V 0126-1-1 (VDE V 0126-1-1):2013-08

Automatic disconnection device between a generator and the public low-voltage grid

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report number: OMK-17JY0139FTSP
Certificate number: U18-0254
Date of issue: 2018-05-04

Certification body



Holger Schaffer

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to DIN EN ISO/IEC 17065



DAkKS

Deutsche
Akkreditierungsstelle
D-ZE-12024-01-00