

ATTESTATION OF CONFORMITY

Issued to: Omnik New Energy Co., Ltd.
Weixin Road No.63, SIP, Suzhou, Jiangsu, China

For the product: Grid-Connected PV Inverter

Trade name:  Omnik New Energy

Type/Model: Omniksol-3k-TL3, Omniksol-3.68k-TL3, Omniksol-4k-TL3

Ratings: Omniksol-3k-TL3
Input: max 580 Vdc, MPPT voltage range: 120-500 Vdc, max 10/10 A, Isc PV: 14 /14 A
Output: 230 Vac, 50/60 Hz, nominal 3000 W, max 3300 VA, nominal 13 A, max 15 A
Omniksol-3.68k-TL3
Input: max 580 Vdc, MPPT voltage range: 120-500 Vdc, max 10/10 A, Isc PV: 14 /14 A
Output: 230 Vac, 50/60 Hz, nominal 3680 W, max 3680 VA, nominal 16 A, max 16 A
Omniksol-4k-TL3
Input: max 580 Vdc, MPPT voltage range: 120-500 Vdc, max 10/10 A, Isc PV: 14 /14 A
Output: 230 Vac, 50/60 Hz, nominal 4000 W, max 4400VA, nominal 17.4A, max 20A

Manufactured by: Omnik New Energy Co., Ltd.
Weixin Road No.63, SIP, Suzhou, Jiangsu, China

Requirements: EN 50438:2013 with deviations according the national network and system protection for the Netherlands

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no. 6028354.51

The examination has been carried out on one single specimen of the product, submitted by the manufacturer.

The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 20 April 2018

Number: 6028354.02AOC

DEKRA Testing and Certification (Shanghai) Ltd.


Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed