

ATTESTATION OF CONFORMITY

Issued to: Omnik New Energy Co., Ltd.
Weixin Road No.63, SIP, Suzhou, Jiangsu, China

For the product: Grid-Connected PV Inverter

Trade name: 
Omnik New Energy

Type/Model: Omniksol-13k-TL3, Omniksol-10k-TL3

Ratings: Omniksol-13k-TL3
Input: max 1000 Vdc, MPPT voltage range: 450-800 Vdc, max 20/10 A, I_{sc} PV: 24/12A
Output: 3/N/PE, 230/400 Vac, 50 Hz, nominal 13000 W, max 13000 VA, max 22 A

Omniksol-10k-TL3
Input: max 1000 Vdc, MPPT voltage range: 350-800 Vdc, max 20/10 A, I_{sc} PV: 24/12A
Output: 3/N/PE, 230/400 Vac, 50 Hz, nominal 10000 W, max 10000 VA, max 17 A

Manufactured by: Omnik New Energy Co., Ltd.
Weixin Road No.63, SIP, Suzhou, Jiangsu, China

Requirements: VDE-AR-N 4105:2011-08
DIN VDE V 0124-100:2013-10

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no. 6018354.52

The examination has been carried out on one single specimen of the product, submitted by the manufacturer.
The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 3 December 2018 Number: 6018354.03AOC

DEKRA Testing and Certification (Shanghai) Ltd.


Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed