



# 太阳能产品认证证书

证书编号：CQC15024127951

### 申请人名称及地址

苏州欧姆尼克新能源科技有限公司  
苏州工业园区唯新路 63 号

### 制造商名称及地址

苏州欧姆尼克新能源科技有限公司  
苏州工业园区唯新路 63 号

### 生产企业名称及地址

苏州欧姆尼克新能源科技有限公司 (V018967)  
苏州工业园区唯新路 63 号

### 产品名称和系列、规格、型号

光伏并网逆变器

Omniksol-5k-TL2, Omniksol-4k-TL2, Omniksol-3k-TL2 (见附件)

### 产品标准和技术要求

NB/T32004-2013 (IIIa, 不含低电压穿越试验)

### 认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC33-461239-2013 认证规则的要求，特发此证。

发证日期：2018 年 01 月 09 日

本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2015 年 06 月 08 日



主任：\_\_\_\_\_



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

T 0005129



# SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC15024127951

## NAME AND ADDRESS OF THE APPLICANT

Omnik New Energy Co.,Ltd.  
No.63 Weixin Road SIP Suzhou China

## NAME AND ADDRESS OF THE MANUFACTURER

Omnik New Energy Co.,Ltd.  
No.63 Weixin Road SIP Suzhou China

## NAME AND ADDRESS OF THE FACTORY

Omnik New Energy Co.,Ltd. (V018967)  
No.63 Weixin Road SIP Suzhou China

## PRODUCT NAME, MODEL AND SPECIFICATION

PV Grid-connected Inverter  
Omniksol-5k-TL2, Omniksol-4k-TL2, Omniksol-3k-TL2(See Appendix)

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T32004-2013(IIIa, Without Low Voltage Ride Through Test)

## TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461239-2013 .

Valid from: Jan.09,2018

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

Date of original issued: Jun.08,2015



President: \_\_\_\_\_

Wang Kejiao



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

T 0005129



# 太阳能产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC15024127951

纸 号: 5129

Omniksol-5k-TL2

直流输入: MPPT 电压范围 120Vdc~550Vdc, 最大直流输入电压 590Vdc,

最大直流输入电流 18A/18A;

交流输出: 单相 230V, 50Hz, 额定交流输出电流 20A, 额定交流输出功率 4600W.

Omniksol-4k-TL2

直流输入: MPPT 电压范围 120Vdc~550Vdc, 最大直流输入电压 590Vdc,

最大直流输入电流 16A/16A;

交流输出: 单相 230V, 50Hz, 额定交流输出电流 17.4A, 额定交流输出功率 4000W.

Omniksol-3k-TL2

直流输入: MPPT 电压范围 120Vdc~550Vdc, 最大直流输入电压 590Vdc,

最大直流输入电流 12A/12A;

交流输出: 单相 230V, 50Hz, 额定交流输出电流 13A, 额定交流输出功率 3000W.

注: 此附录与证书同时使用时有效。



主任:

A handwritten signature in black ink, appearing to be '王克博' (Wang Kebo).



## 中国质量认证中心

中国 北京 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>